

# Specification Sheet ISO 12944-5 Ref: (C4F) Steelwork

**New Construction** 

### Environment to ISO12944-2: C4 Environment - Industrial Areas, Chemical Plants and Swimming Pools Etc.

## Durability (Life to First Major Maintenance): High Durability (15-25 years)

#### **Surface Preparation:** Blast Clean to Sa2½ BS EN ISO 8501-1:2007 - Surface Profile between 50 - 75µm

| Coat | Product                    | Dreduct Tures        | Film Thickness µm |     | TSR       | Volume   | Mixing | Pot Life |
|------|----------------------------|----------------------|-------------------|-----|-----------|----------|--------|----------|
|      |                            | Product Type         | Dry               | Wet | (sqm/ltr) | Solids % | Ratio  | 23°C     |
| 1st  | Macropoxy <sup>®</sup> 400 | Zinc Phosphate Epoxy | 240               | 343 | 2.9       | 70       | 7:1    | 1½ hrs   |

TSR = Theoretical Spread Rate

| Product | Thinner /                                      | Touch Dry | Recoat | Touch Dry | Recoat | Sag         | Colour              | Pack       | Product Information                |  |
|---------|--|-----------|--------|-----------|--------|-------------|---------------------|------------|------------------------------------|--|
| Code    | Cleansers                                      | 15°C      | 15°C   | 23°C      | 23°C   | Tolerance   | Range               | Size       |                                    |  |
| 400     | No.2 for Thinning -<br>No.9/13 for<br>Cleaning | 1½ hrs    | 5 hrs  | 1 hr      | 3½ hrs | 400µm d.f.t | Limited Inc,<br>MIO | 20 & 5 ltr | 400 Data Sheets and<br>Information |  |

D.F.T = Dry Film Thickness

#### Notes:

- 1 Dry film thicknesses (d.f.t.) quoted are minimum nominal as defined by BS EN ISO 12944-5.
- 2 ISO12944 states that Durability is not a guarantee time. Durability should be considered as the coating design life, where regular minor maintenance should be scheduled to achieve the required life to first major maintenance.
- 3 Stripe coat all edges, welds and areas of difficult access, to ensure full film thickness.
- 4 Coated steelwork should be protected to prevent prolonged contact with water, e.g. ponding.
- 5 All epoxy coatings will discolour and chalk progressively. Later application (site touch-up) may be noticeable.
- 6 All materials should be obtained from Sherwin-Williams® and must be applied in accordance with our product data sheets.
- 7 Dry film thickness can be applied as 1 or 2 coats. Certification for 2 coat system is available from Sherwin-Williams® Technical Customer Support.
- 8 For fire protection systems, please contact Sherwin-Williams®.
- 9 This specification is offered as guidance only. To ensure that the most appropriate materials are used, please contact Sherwin-Williams<sup>®</sup> with the project details.